

OFFICE USE ONLY  
 Log No. 76107  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32246

1. OWNER TAB ADDRESS AT WELL LOCATION In Wash  
 MAILING ADDRESS 3017 N 5th M Stewart

2. LOCATION SW 1/4 S 19 T 20 N R 62 E Clark County  
 PERMIT NO. DW 1000B Issued by Water Resources | 140-32696-001 Parcel No. | \_\_\_\_\_ Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other DOT

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Dirt &amp; sand</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Med sand &amp; gravel</u>		<u>5</u>	<u>10</u>	<u>5</u>
<u>Med sand w/ silty clay</u>		<u>10</u>	<u>30</u>	<u>20</u>

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 30 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>PVC</u>	<u>3/16</u>	<u>0</u>	<u>30</u>

Perforations:  
 Type perforation slot  
 Size perforation .032  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 10 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 10 feet to 30 feet



Date started 3-27-99 19\_\_\_\_  
 Date completed \_\_\_\_\_ 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 7 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BDK Contractor  
 Address 536 E. Main Street Contractor  
Outpar.

Nevada contractor's license number issued by the State Contractor's Board 31246  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. M 1768

Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 4-10-99