WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76116
Permit No.
Basin 212

NOTICE OF INTENT NO. 18913

1. OWNER La Mar Noorda
MAILING ADDRESS 4250 Production Ct.
Las Vegas, NV 89115

ADDRESS AT WELL LOCATION Horse & Garhime 6575 HORSE DR

2. LOCATION NW ¼ SW ¼ Sec. 11 T 19 X N/S R 60XX E Clark County

PERMIT NO. Issued by Water Resources | 125-11-304-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
XX Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable XX Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	40	40
White Calachi, boulds.		40	60	20
Brown clay, white calachi, boulders		60	80	20
White calachi, bldrs		80	100	20
Cemented brown clay, boulders		100	120	20
Brown clay, some white clay & gravel stringers		120	600	480

AUG 9

Date started July 28, 19 99
Date completed August 2, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	600 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+1	600

Perforations:
Type perforation mill slot
Size perforation 1/8
From 290 feet to 418 feet
From 503 feet to 587 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 62
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☐ Neat Cement XX Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 62 feet to 600 feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co., Inc. (Contractor)
Address 7227 Hauck Street (Contractor)
Las Vegas, NV 89118

Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2074
Signed Richard Thompson (By driller performing actual drilling on site or contractor)
Date August 3, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627