

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32249

1. OWNER TAB Contractors ADDRESS AT WELL LOCATION 701 WASH
 MAILING ADDRESS NLV NV 5 Sundhill

2. LOCATION Sw 1/4 S 1/4 Sec 19 T 20 N 62 E Clark County
 PERMIT NO. 146-20101000 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVG
 Air Other Bucket

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------|--------------|------|----|------------|
| Fill + Concrete | | 0 | 13 | 13 |
| Sandy clays | | 13 | 23 | 10 |
| Sand + gravel | | 23 | 25 | 2 |
| Silty clay w/ Sands | | 25 | 40 | 15 |

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)
 From 24 Inches To 40 Feet
 From 0 Feet To 40 Feet
 From 0 Feet To 40 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>8</u> | <u>PVC</u> | <u>5/16</u> | <u>0</u> | <u>40</u> |

Perforations:
 Type perforation Slot
 Size perforation 0.32

From 10 feet to 40 feet
 From 10 feet to 40 feet
 From 10 feet to 40 feet
 From 10 feet to 40 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Poured

Gravel Packed: Yes No
 From 0 feet to 40 feet

9. WATER LEVEL
 Static water level 16 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 69.10 °F Quality Good

Date started 3-9-99, 19____
 Date completed 3-9-99, 19____

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |
| | | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GDC Contractor
 Address 536 E Maitland Ontario CA Contractor

Nevada contractor's license number 31246 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller MA68

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 3-31-99