DRILL 4S WELLS

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76221
Permit No.
Basin 212

NOTICE OF INTENT NO. 5270

1. OWNER CLARK County Sanitation
MAILING ADDRESS 5857 EPLAMINO
LV NV 89102

ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ NE ¼ Sec. 27 T. 21S N/S R. 62 E. CLARK County
PERMIT NO. DW 1094 (Issued by Water Resources) 161-27-599-002 & 001 (Parcel No.) TROPICANA EAST (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other DWATER

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ASPHALT & TYPE 2 | | 0 | 2 | 2FT |
| DRY SILT & CLAY | | 2 | 9.5 | 7.5 |
| WET SILT, SANDY CLAY | X | 9.5 | 20 | 11.5 |

WELL 09

Date started 9-2, 19 98
Date completed 9-7, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased WELL POINT Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12 Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |
| | | | | |
| | | | | |

Perforations:
Type perforation SAND SCREEN
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 20 feet to 0 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SOUTHWEST PAVING (Contractor)
Address (Contractor)

Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed Donald L Wall (By driller performing actual drilling on site or contractor)
Date 9-15-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627