

DRILL 45 WELLS

76257

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 76257  
Permit No. \_\_\_\_\_  
Basin. 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 5270

1. OWNER CLARK County Sanitation ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 5857 E PLAMINDO  
LV NV 89102  
2. LOCATION NE 1/4 NE 1/4 Sec. 27 T. 21 S N/S R 62 E CLARK County  
PERMIT NO. DW 1094 161-27-599-0024001 TROPICANA EAST  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other DWATER  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>ASPHALT &amp; TYPE 2</u>		<u>0</u>	<u>2</u>	<u>2 FT</u>
<u>DRY SILT &amp; CLAY</u>		<u>2</u>	<u>9.5</u>	<u>7.5</u>
<u>WET SILT, SANDY CLAY</u>	<u>*</u>	<u>9.5</u>	<u>20</u>	<u>11.5</u>
<u>Well 45</u>				

8. WELL CONSTRUCTION  
Depth Drilled 20 Feet Depth Cased WELL POINT Feet  
HOLE DIAMETER (BIT SIZE)  
From 12 Inches To \_\_\_\_\_ Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Pt. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
Type perforation SAND SCREEN  
Size perforation \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 20 feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 8 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cool °F Quality \_\_\_\_\_

Date started 9-2 1998  
Date completed 9-7 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name SouthWest Paving Contractor  
Address \_\_\_\_\_ Contractor  
Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661  
Signed Donald L. Walsh  
By driller performing actual drilling on site or contractor  
Date 9-15-98