WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76307
Permit No.
Basin 83

NOTICE OF INTENT NO. 16437

1. OWNER (SPPCO.) NEVADA Power Co. Sierra Pacific Power Co.
MAILING ADDRESS 6100 Neil Road P.O. Box 10100 Reno, NV. 89520-0024
ADDRESS AT WELL LOCATION Fort Churchill Power Company STATION Lyon County, NV.

2. LOCATION SE ¼ NE ¼ Sec. 28 T. 19 N/S R. 21 E. Lyon County
PERMIT NO. | Issued by Water Resources | 14-091-08 15 | Parcel No. | 25 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Silt		0	6'	
COBBLE/ROCK/caliche		6'	10'	
Sandy Silt		10'	20'	

DCNR/DWR Received FEB 22 1999 LAS VEGAS OFFICE

Date started DEC. 12, 1998
Date completed DEC. 12, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	20 Feet	
8 Inches	0 Feet	20 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	–	Sch. 40	0	20
2	–	Sch. 40	0	20

Perforations:
Type perforation .020 SLOT
Size perforation .020
From 5 feet to 15 feet
From 5 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 4 FT.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 20 feet to 4 feet

9. WATER LEVEL
Static water level 10' feet below land surface
Artesian flow – G.P.M. – P.S.I.
Water temperature – °F Quality –

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mike Lester (WEST HYDRAH) Contractor
Address 1016 EL KATELLA AVE Contractor
ANAHEIM, CA. 92805
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1935
Signed By driller performing actual drilling on site or contractor
Date JAN 10, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627