

OFFICE USE ONLY
 Log No. 76321
 Permit No. _____
 Basin 222



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17115

1. OWNER Peppermill Casinos, Inc. ADDRESS AT WELL LOCATION Oasis RV PARK 1134 Mesquite Blvd. Mesquite, NV 89024
 MAILING ADDRESS 90 W. Grove Street Reno, NV 89509 ATTN: Carole Hyde
 2. LOCATION SE 1/4 NE 1/4 Sec. 18 T. 13 N. R. 71 E. Clark County
 PERMIT NO. MO-2362 Issued by Water Resources Parcel No. 001-18-602-005 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. MW-5 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Asphaltic Concrete</u>		<u>0</u>	<u>4"</u>	<u>4"</u>
<u>Brown, moist, loose sandy-grained Sand w/ silt (SP-SM)</u>		<u>4"</u>	<u>13'</u>	<u>12 1/2'</u>
<u>Brown, moist, loose Silty Sand (SM)</u>		<u>13'</u>	<u>45'</u>	<u>32'</u>
<u>water @ 35' bgs</u>				

8. WELL CONSTRUCTION
 Depth Drilled 45 Feet Depth Cased 42 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 45 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.125"</u>			<u>0</u>	<u>42</u>

Perforations:
 Type perforation Factory slotted
 Size perforation 0.020"
 From 27 feet to 42 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 25 FT. (APX) Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite
 Gravel Packed: Yes No
 From 25 feet to 42 feet

9. WATER LEVEL
 Static water level 35.3 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature N/C °F Quality N/C

Date started 29 June 1999
 Date completed 29 June 1999

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
N/C	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name SPECTRUM EXPLORATION Contractor
 Address 16662 GEMINI LANE HUNTINGTON BEACH CA 92674 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 34699
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2059
 Signed Sh. Gault
 By driller performing actual drilling on site or contractor
 Date July 20-99

