

OFFICE USE ONLY  
 Log No. 76323  
 Permit No. T107  
 Basin

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 411660

1. OWNER Tom Clemens ADDRESS AT WELL LOCATION #19 Corner Smith Valley  
 MAILING ADDRESS  
 2. LOCATION S 1/2 1/4 NE 1/4 Sec 28 T. 11 N/S R. 24 E Lyon County  
 PERMIT NO. 109-122-10  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil, Clay, Sand		1	7	
Sand, Gravel		7	86	
Clay		86	110	
Gravel		110	143	
Clay		143	210	
Gravel Sand		210	216	
Clay		216	283	
Gravel		283	288	
Clay	317	288	317	
Gravel	340	317	340	
Clay	345	340	345	
Gravel		345	358	
Clay	358	345	358	
		358	360	

8. WELL CONSTRUCTION  
 Depth Drilled 360 Feet Depth Cased 360 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/8 Inches To 3 1/2 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1 5/8	13	1 1/8	1	20
2 1/4	3	2 1/4	20	360

 Perforations:  
 Type perforation Mill Rest  
 Size perforation 3 1/2 x 6 x 8  
 From 240 feet to 360 feet  
 From 280 feet to 330 feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 200 feet to 360 feet

Date started 5/1/99  
 Date completed 5/21/99

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	60-65		4 hrs

9. WATER LEVEL  
 Static water level 110 feet below land surface  
 Artesian flow G.F.M. P.S.I.  
 Water temperature C °F Quality good  
 10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name: Tom Clemens Contractor  
 Address: 20 599 Contractor  
 SS NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board: 0081841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1870  
 Signed: [Signature]  
 By driller performing actual drilling on site or contractor  
 Date: 6/8/99

RECEIVED  
 99 JUN 16 AM 10:19  
 STATE ENGINEERS OFFICE