

OFFICE USE ONLY  
 Log No. 763.27  
 Permit No. 105  
 Basin. I

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42124

1. OWNER Russel Resney ADDRESS AT WELL LOCATION 1879 Grey CT GU NV 89410  
 MAILING ADDRESS 1403 Alder Gate CT. GU NV 89410

2. LOCATION SE 1/4 NW 1/4 Sec. 1 T 12 R 20 E Douglas County  
 PERMIT NO. 23-610-060 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Large Cobles Sandy Clay		0	50	50
Cobles Gravelly Clay		50	140	90
Gravelly Br. Clay Sand		140	190	50
Mostly Gravelly Gravel and Sand Some Br. Clay	✓	190	210	20
Brown Clay		210	215	
Gravel & Sand little Clay	✓	215	240	

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 50 Feet  
10 Inches 50 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.158</u>	<u>+1</u>	<u>200</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 2/32  
 From 200 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 112 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NU Drilling Inc. Contractor  
 Address 75 Lewers CR Rd Carson Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 136974  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5-24-99

Date started 5-19 1999  
 Date completed 5-21 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air Lift</u>	<u>30+</u>	<u>Total</u>	<u>1</u>

RECEIVED  
 99 JUN - AM 11:33  
 STATE ENGINEERS OFFICE