WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76333
Permit No.
Basin 105

NOTICE OF INTENT NO. 38892

1. OWNER Greg Davies Construction
MAILING ADDRESS 1 Fish Springs Rd Gardnerville NV 89410
ADDRESS AT WELL LOCATION 1760 Merino Crt. Gardnerville NV. 89410

2. LOCATION NE ¼ NE ¼ Sec. 14 T. 12 N S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 29-550-03 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Course Cobbles and Boulders		3	68	65
Brown Clay		68	91	23
Course Sand and Cemented Gravels		91	137	46
Brown Clay		137	170	33
Fractured Cobbles and Gravels	XX	170	190	20

RECEIVED 99 MAY 17 PM 4:53 [illegible]

Date started 5-4, 1999
Date completed 5-7, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	40	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	190

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 170 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 190 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow ~~30~~ G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Contractor
Address Contractor
Capital City Well Drilling
20 Kit Kat Drive
Carson City, NV 89706

Nevada contractor's license number issued by the State Contractor's Board 41775

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed Michael L Hack
By driller performing actual drilling on site or contractor

Date 5-11-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627