

OFFICE USE ONLY
 Log No. 76337
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36276

1. OWNER Tim & Dian Shitz ADDRESS AT WELL LOCATION 2480 Shena Terrace
 MAILING ADDRESS 2480 Shena Terrace Gardnerville NV
Gardnerville NV 89410
 2. LOCATION NE 1/4 SW 1/4 Sec. 31 T. 12 N. R. 21 E Douglas County
 PERMIT NO. 23-160-23 Parcel No. _____ Subdivision Name Fish Springs

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Boulders		0	13	13
BR Sandy Clay		13	18	5
Gravel (Med)		18	91	73
Be Clay		91	162	71
Dark Sandy Clay		162	210	48
DARK CLAY		210	347	137
Sand Med		347	358	11
Sand & Gravel	✓	358	385	27
DARK CLAY		385	390	5

8. WELL CONSTRUCTION
 Depth Drilled 390 Feet Depth Cased 390 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 60 Feet
9 1/8 Inches 60 Feet 390 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>390</u>

Perforations:
 Type perforation Factory Milled
 Size perforation 10 x 3 1/2 Row
 From 370 feet to 390 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 390 feet

9. WATER LEVEL
 Static water level 91 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality Good

Date started 4-7 1999
 Date completed 4-15 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>+20</u>		<u>2 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eddco Exploration Inc. Contractor
 Address 7780 CURRY Rd Contractor
Fallon NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673 A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-22-99