202

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76348
Permit No.
Basin 105

NOTICE OF INTENT NO. 20401

1. OWNER Douglas Co. Sewer Improvement Dist #1
MAILING ADDRESS JWA Consulting Engineers
P.O. Box 1819 Zephyr Cove NV 89448
ADDRESS AT WELL LOCATION Douglas County Sewer Improvement District No. 1

2. LOCATION NW ¼ ¼ Sec 18 T 13 N/S R 21 E Douglas County
PERMIT NO. NEV80033 (Issued by Water Resources)
APN-23-01-67 (Parcel No.)
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other ARCH

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Brown silt		2	9	7
Sand & gravel		9	49	40
Layered sand & gravel		49	67	18
Brown silt w/sand		67	91	24
Cobbles interbedded w/ silt		91	101	10
Fine silt interbedded w/fine sand		101	210	109
Silty clay, stiff		210	214	4
Coarse sant & gravel		214	225	11
Fine sand		225	237	12
Brown silty clay w/fine		237	252	15

RECEIVED 99 JUN -7 PM 2:28 STATE ENGINEER'S OFFICE

Date started May 13, 1999
Date completed May 17, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air lift	20-25	NM	5
Test pump	10		5

8. WELL CONSTRUCTION
Depth Drilled 252 Feet Depth Cased 252 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	100 Feet
6 5/8 Inches		0 Feet	225 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28	0.25	0	100
6 5/8	17	0.25	0	225

Perforations:
Type perforation Continuous wire wrap
Size perforation 0.020"
From 225 feet to 245 feet
From 245 feet to 252 sump feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature NM °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Beylik Drilling, Inc. (Contractor)
Address 3429 Longview Drive (Contractor)
North Highlands, CA 95660-5804
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656-T1
Signed Robert A. Glascott Jr. (By driller performing actual drilling on site or contractor)
Date June 3, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627