

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21124

1. OWNER Huntsman Ranch LLC ADDRESS AT WELL LOCATION Shoshone, NV.
 MAILING ADDRESS Box 189
Enterprise UT 84725

2. LOCATION NE 1/4 NE 1/4 Sec. 13 T 12 N/R. 67 E White Pine County
 PERMIT NO. 1882763521 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic Irrigation Test
 Deepen Abandon Other..... Municipal/Industrial Monitor Stock
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness ft
		0	8	8
Sand gravel rocks		8	27	19
Clay rocks		27	44	17
gravel rocks		44	59	15
Clay sand		59	81	22
gravel rocks	X	81	82	6
Clay gravel rocks		87	92	5
gravel rocks	X	92	110	8
Clay rocks		110	113	3
gravel rocks	X	113	135	22
Clay gravel		135	138	3
gravel rocks	X	138	145	7
Clay rocks		145	154	9
gravel rocks	X	154	163	9
Clay gravel		163	185	22
gravel rocks	X	185	194	9
Clay		194	196	2
gravel rocks	X	196	235	39
Clay sand		235	241	6
gravel rocks	X	241	269	28
gravel sand rocks	X	269	299	30
Clay sand		299	307	8

RECEIVED JUL 26 AM 11:11
 GPS as per 71525 ROG
 N 38° 54' 22.0" NAD 83
 W 114° 23' 38.1"

8. WELL CONSTRUCTION
 Depth Drilled 307 Feet Depth Cased 307 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
24 Inches 0 Feet 307 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"	42	.250	0	307

Perforations:
 Type perforation mill
 Size perforation 5/32 x 2 1/2 16 rows
 From 80 feet to 307 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 307 feet

9. WATER LEVEL
 Static water level 36 feet below land surface
 Artesian flow NA G.P.M. _____ P.S.I. _____
 Water temperature cold °F Quality good

Date started June 21 1999
 Date completed July 14 1999

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
lineshaft	1300	194'	12 hr

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Gardner Drilling Contractor
 Address Box 610 Contractor
Enterprise UT 84725
 Nevada contractor's license number issued by the State Contractor's Board 0031759
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1710
 Signed Dale Gardner
 By driller performing actual drilling on site or contractor
 Date July 19 1999