WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76357
Permit No. 99
Basin

NOTICE OF INTENT NO. 86830

1. OWNER Dave Metz
MAILING ADDRESS 6137 Torrington DR Reno NV. 89510
ADDRESS AT WELL LOCATION 1032 Dickhill Rd Carson City NV. 89704

2. LOCATION SW ¼ NE ¼ Sec. 30 T. 16 N/S R. 20 E. Washoe County
PERMIT NO. Issued by Water Resources | Parcel No. 55-320-55 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Course DG Granite Rusty Stained Loose		0	187	187
DG Granite medium to Hard.		187	286	99
DG Granite. (Hard) Granite Stained Fine, Rusty.		286	410	124
		410	545	135
Light Gray Granite Very Hard				
Course DG Granite medium formation. Small Fractures Very Large Granite Boulders 12'-15' Thick. Loose In Between Hard Granite Boulder	X	545	580	35
	X	580	595	15
DG Fractured Granite with Fractured Water Zones	XX	595	640	45

Date started 7-7, 1999
Date completed 7-20, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-18	65	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 640 Feet Depth Cased 640 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	410 Feet
8 3/4 Inches	410 Feet	640 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16 5/8	13.03	.188	0	640

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 600 feet to 640 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 640 feet

9. WATER LEVEL
Static water level 465 feet below land surface
Artesian flow G.P.M. 15-18 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Capital City Well Drilling
Contractor
Address 20 Kit Kat Drive Carson City, NV 89706
Contractor

Nevada contractor's license number issued by the State Contractor's Board 41775

Nevada driller's license number issued by the Division of Water Resources, the Nevada State 1905

Signed Michael L. Hoel
By driller performing actual drilling on site or contractor

Date 7-21-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627