WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76359
Permit No.
Basin 45

NOTICE OF INTENT NO. 36964

1. OWNER BERNARD (ED) BROOKS
MAILING ADDRESS
ADDRESS AT WELL LOCATION NONE

2. LOCATION SE ¼ NE ¼ Sec. 26 T. 33 N/S R. 57 E. ELKO County
PERMIT NO. N/A (Issued by Water Resources) LOT 13, BLK S (Parcel No.) PLEASANT VALLEY ESTATES (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, sand, gravel & Boulder		0	26	26
Consolidated granitic rock		26	65	39
Coarse gravel		65	70	5
Clay		70	97	27
Sand & gravel	✓	97	102	5
Alternating layers of clay, sand & gravel with water ~~quantity~~ quantity increasing	✓	102	145	43
Clay		145	149	4
T.D. 149				

Date started 6-6 ~~[illegible]~~, 1999
Date completed 6-11 ~~[illegible]~~, 1999

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	10	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 149 Feet Depth Cased ~~100~~ 149 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	97 Feet
6 Inches		97 Feet	149 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1.00	149

Perforations:
Type perforation Torch Cut
Size perforation 1/16 x 6" x 2 per foot
From feet to feet
From 100 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 97
Placement Method: ☑ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow No. G.P.M. P.S.I.
Water temperature Cold °F Quality Excellent

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MATH DRILLING CO. (Contractor)
Address 203 PINE ST. (Contractor)
ELKO, NV. 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-27-99

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627