

REPORT NO. 99.34

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

LOG NO. 76399  
PERMIT NO. 99  
BASIN \_\_\_\_\_

NOTICE OF INTENT NO. 41595

OWNER Mike Coscuna  
MAILING ADDRESS 15560 Rancho Drive Reno, Nv 89506

ADDRESS OF WELL 15560 Rancho Drive  
Reno, Nv 89506

2. WELL LOCATION NE 1/4 NE 1/4 SEC. 15 T 23N R 18 E Washoe COUNTY

PERMIT NO \_\_\_\_\_ PARCEL NO 078-151-01 SUBDIVISION NAME Rancho Haven

3. TYPE OF WORK

- New Well
- Replace
- Recondition
- Deepen
- Plug
- Other

4. PROPOSED USE

- Domestic
- Municipal/Industrial
- Irrigation
- Monitor
- Test
- Stock

5. WELL TYPE

- Cable
- Air
- Rotary
- Mud
- RVC

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
<i>AQUA'S EVALUATION</i>				
<i>SEE ORIGINAL LOG</i>				
<i>30 JUL - 6 PM 1:06</i>				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Depth Cased \_\_\_\_\_

HOLE DIAMETER (BIT SIZE)

\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8			0	94
5 9/16			36	358

PERFORATIONS:

Type Perforation Factory Size Perforation \_\_\_\_\_

From 318 Feet to 358 Feet

From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

SURFACE SEAL:

- Yes  No
- SEAL TYPE:  Neat Cement
- Cement Grout
- Concrete Grout
- PLACEMENT METHOD:  Pumped  Poured

GRAVEL PACKED:

- Yes  No
- From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

Notes : Tagged bottom @ 385'. Tried to pull liner for deepening, couldn't. Tried to perforate liner, couldn't get inside w/5" perf. Plugged w/20 50# bags Baroid Aquaguard. Grout circulated on back side of liner. 50# bag holeplug & 3.5 bags of cement for top plug.

Date Started 6/23/99 Date Completed 6/23/99

7. WELL TEST DATA

TEST METHOD	GPM	DRAWDOWN	TIME (HRS)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Develop			
358'	2.2		

9. WATER LEVEL

Static Water Level 152 Feet Below Land Surface

Artesian Flow \_\_\_\_\_ GPM \_\_\_\_\_ PSI

Water Temperature \_\_\_\_\_ F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc

Address 675 Edison Way  
Reno, Nv 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. \_\_\_\_\_

ON SITE 1981

Signed Roger Whitehall

By driller performing actual drilling on site or contractor

Dated July 1, 1999