

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18470

1. OWNER Darrell Thompson ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS \_\_\_\_\_  
821 E. Carberry Pahump, NV 89041 821 E. Carberry Pahump, NV 89041  
2. LOCATION NW 1/4 SE 1/4 Sec 3 T 21 N/S R 53 E Tye County \_\_\_\_\_  
PERMIT NO. 44-231-11 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown clay</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>grey clay</u>		<u>10</u>	<u>29</u>	<u>19</u>
<u>caliche</u>		<u>29</u>	<u>64</u>	<u>35</u>
<u>light brown clay</u>	<u>X</u>	<u>64</u>	<u>79</u>	<u>15</u>
<u>caliche</u>	<u>X</u>	<u>79</u>	<u>82</u>	<u>3</u>
<u>grey clay</u>	<u>X</u>	<u>82</u>	<u>140</u>	<u>58</u>

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet  
HOLE DIAMETER (BIT SIZE)  
From 12 Inches To 140 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>0</u>	<u>PVC</u>	<u>0</u>	<u>140</u>

Perforations:  
Type perforation Factory  
Size perforation Saw  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 120 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 140 feet

9. WATER LEVEL  
Static water level 54 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 61.0 °F Quality good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Larry Water Well Service Contractor  
Address P.O. Box 3392 Contractor  
Pahump, NV 89041  
Nevada contractor's license number issued by the State Contractor's Board: 0035901  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1916  
Signed Larry Jenkins  
By driller performing actual drilling on site or contractor  
Date 6-28-99

Date started 5-6-99, 19\_\_\_\_  
Date completed 6-20-99, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>5</u>	<u>1/2</u>

