


STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. **76439**
 Permit No. **162**
 Basin **162**



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **18883**

1. OWNER **BSLE** ADDRESS AT WELL LOCATION **4321 W. Venza**
 MAILING ADDRESS **4321 W. Venza**
Pahrump, NV 89048

2. LOCATION **SE 1/4 SE 1/4 Sec. 26 T 20S N/S R 52E E Nye** County **Nye**
 PERMIT NO. **28-612-16** Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
light brown loam		0	14	14
brown loam and clay		14	22	8
grey loam		22	35	13
dark grey gravel		35	39	4
grey caleche	x	39	68	29
light grey clay	x	68	140	72

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From **120** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL
 Static water level **59** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

Date started **7/14/99**, 19____
 Date completed **7/14/99**, 19____


7. WELL TEST DATA

TEST METHOD:	Time (Hours)
<input type="checkbox"/> Bailer	
<input type="checkbox"/> Pump	
<input type="checkbox"/> Air Lift	
G.P.M.	
Draw Down (Feet Below Static)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed 
 By driller performing actual drilling on-site of contractor
 Date **7-26-99**

