KMW-15

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76458
Permit No.
Basin 212

NOTICE OF INTENT NO. 19003

1. OWNER: Rebel Oil
MAILING ADDRESS: 3225 N. Las Vegas Blvd, Las Vegas, Nevada
ADDRESS AT WELL LOCATION: Same

2. LOCATION: SE ¼ SW ¼ Sec. 7 T. 20 N/S R. 62 E. Clark County
PERMIT NO. (Issued by Water Resources) 140-07-408-005 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED: ☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Material		0	4	
Brown silty sand, little coarse sands trace fine gravels trace clay		4	9	
Tan brown silty sand trace coarse sands, trace clay		9	16	
Tan brown silty sands, some fine gravels, trace coarse gravels		16	18	
tan silty sands, little coarse sands, trace clay		18	32	
tan silty sand, little coarse sands, trace fine gravels, trace clay		32	40	
tan silty clay, little sands, trace coarse sands		40	60	
grades into trace fine gravels		60	67	

Date started 8-9, 1999
Date completed 8-9, 1999

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 67 Feet Depth Cased 32 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	67 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	—	—	0	32

Perforations:
Type perforation: SCH 40 PVC
Size perforation: .020
From 32 feet to 67 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 12
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 22 feet to 67 feet

9. WATER LEVEL
Static water level ~55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) The Verde Companies, Inc
Address (Contractor) 301 W. Deer Valley Rd #1, Phoenix, Arizona 85027
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2075T1
Signed (By driller performing actual drilling on site or contractor)
Date 9/1/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627