WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76512
Permit No. T
Basin 105

NOTICE OF INTENT NO. 20402

1. OWNER Douglas Co. Sewer Improvement Dist. #1
MAILING ADDRESS JWA Consulting Engineers
P.O. Box 1819 Zephyr Cove NV 89448

ADDRESS AT WELL LOCATION Douglas County Sewer Improvement District No. 1

2. LOCATION NW ¼ ¼ Sec 18 T 13 N/S R 21 E Douglas County
PERMIT NO. NEV 80033 (Issued by Water Resources) APN23-01-67 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other ARCH

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Fine silt & sand		2	88	86
Gravel		88	92	4
Silty sand w/some				
interbedded clay		92	180	88
~~XXXX~~				
Coarse sand & gravel	Yes	180	202	22
Silty clay		202	209	7

Date started May 17, 1999
Date completed May 19, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air lift	70	NM	5
Test pump	55/75/90		5

8. WELL CONSTRUCTION
Depth Drilled 209 Feet Depth Cased ~~200~~209 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches	0 Feet	100 Feet	
6 5/8 Inches	100 Feet	209 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28	0.25"	0	100
6 5/8	17	0.25	0	181

Perforations:
Type perforation Continuous wire wrap
Size perforation 0.02"
From 181 feet to 201 feet
From 201 feet to 209 sump feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 112 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature NM °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Beylik Drilling, Inc. (Contractor)
Address 3429 Longview Drive (Contractor)
North Highlands, CA 95660-5804
Nevada contractor's license number issued by the State Contractor's Board 0007055A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656-T1
Signed Robert A. Glasscott Jr. (By driller performing actual drilling on site or contractor)
Date June 3, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627