



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340.

NOTICE OF INTENT NO. 19057

1. OWNER Joseph Reece ADDRESS AT WELL LOCATION 1171 Hardy Lane
MAILING ADDRESS 1171 Hardy Lane Primm, NV 89048 Primm, Nevada 89048

2. LOCATION SE 1/4 SE 1/4 Sec 17 T. 20 S N/2 R. 53 E County Nye
PERMIT NO. Cal Vegas Ranchos Unit 7 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	5	5'
white clay		5'	10'	5'
Caliche		10'	20'	10'
white clay		20'	30'	10'
brown clay		30'	40'	10'
caliche		40'	45'	5'
White Clay		45'	60'	15'
brownst clay		60'	85'	15'
caliche		85'	95'	10'
brownst clay		95'	120'	25'
caliche		120'	125'	5'
white clay		125'	130'	5'
brown clay		130'	140'	10'

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
From 12 Inches To 140 Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	140

Perforations:
Type perforation 3 1/2" cut
Size perforation 1/8" X 3"
From 120 feet to 140 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started August 3 1999
Date completed August 6 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ray Whillon Drilling Contractor
Address P.O. Box 265 Contractor
Primm, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 0035704
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116

Signed Fourest LaRue
By driller performing actual drilling on site or contractor
Date 9/2/99