


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 76521  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

*AMENDED*

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18905

1. OWNER **Robert Hunkins**  
 MAILING ADDRESS **3140 W. Windsong Pahrump, NV 89048**  
 ADDRESS AT WELL LOCATION **3140 W. Windsong**

2. LOCATION **NE 1/4 NE 1/4 Sec. 13 T 20S N/S R 52E E Nye** County  
 PERMIT NO. **41-401-28** Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>brown clay</b>		0	8	8
<b>grey clay</b>		8	48	40
<b>See next line</b>	x	48	126	78
<b>brown clay &amp; brown calciche strings</b>				
<b>light brown calciche</b>	x	126	140	14

8. WELL CONSTRUCTION  
 Depth Drilled **140** Feet Depth Cased **140+1** Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
**11** Inches **0** Feet **140** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>3.7</b>	<b>.280</b>	<b>0</b>	<b>140</b>

Perforations:  
 Type perforation **sawcut**  
 Size perforation **.188**  
 From **115** feet to **140** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **140** feet

**DCNR/DWR RECEIVED**

**OCT 19 2006**

**LAS VEGAS OFFICE**

Date started **8/19/1999** \_\_\_\_\_ 19  
 Date completed **8/18/1999** \_\_\_\_\_ 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level **52** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Strickland Construction Co., Inc.** Contractor  
 Address **5801 S. Homestead** Contractor  
**Pahrump, NV 89048**  
 Nevada contractor's license number issued by the State Contractor's Board **40277**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**  
 Signed \_\_\_\_\_ By driller performing actual drilling on-site or contractor  
 Date **10-17-06**