WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76535
Permit No.
Basin 212

NOTICE OF INTENT NO. 15598

1. OWNER Paradise Development Co
MAILING ADDRESS 3111 S. Maryland Pkwy LV NV 89109
ADDRESS AT WELL LOCATION 3284 S. Maryland Pkwy

2. LOCATION SW ¼ SW ¼ Sec. 11 T. 21 R/S R 61 E CLARK County
PERMIT NO. NA (Issued by Water Resources) 162-11-401-006 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
Fill asphalt over type II		0	1.5	
CLAYEY SAND		1.5	5.5	
SANDY CLAY		5.5	7.5	
SILTY CLAY		7.5	12.5	
SILTY SAND		12.5	15	
CLAYEY SAND	Y	15	17	
SANDY CLAY	Y	17	18.5	
CLAYEY SAND	Y	18.5	26	

Date started 8/23, 1999
Date completed 8/23, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 26 Feet, Depth Cased 25.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 1/2 Inches	0 Feet	26 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch. 40	0	25.5

Perforations:
Type perforation slotted screen
Size perforation .010 inch
From 10.5 feet to 25.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 26 feet

9. WATER LEVEL
Static water level 15.28' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants (Contractor)
Address 4343 So Polaris Ave. (Contractor)
Las Vegas, Nevada 89103
Nevada contractor's license number issued by the State Contractor's Board M1944
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed Thomas M. Beall (By driller performing actual drilling on site or contractor)
Date 9-7-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627





CONFIDENTIAL
Received
SEP 9 1999

EXPLANATION:

MW-1 – MONITORING WELL AND NUMBER
B: – BENZENE, CONCENTRATION IN ug/L
T: – TOLUENE, CONCENTRATION IN ug/L
E: – ETHYLBENZENE, CONCENTRATION IN ug/L
X: – XYLENE, CONCENTRATION IN ug/L
MTBE: – METHYL T-BUTYL ETHER, CONCENTRATION IN ug/L

SAMPLE DATE: AUGUST 24, 1999

CLIENT: REALTY HOLDINGS GROUP	Terracon	MONITORING WELL DIAGRAM
PROJECT: SMOG BUSTERS		PROJECT NO.: 64997053 / FIGURE: 4