WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76544
Permit No.
Basin 212

NOTICE OF INTENT NO. 18658

1. OWNER PIONEER CHLOR ALKALI
MAILING ADDRESS 8000 LAKE MEAD DR. HENDERSON, NV
ADDRESS AT WELL LOCATION 8000 LAKE MEAD DR. HENDERSON NV.

2. LOCATION SW ¼ SW ¼ Sec. 12 T. 22 N/S R. 62 E. CLARK County
PERMIT NO. (Issued by Water Resources) 178-12301-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other H.S.A.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL WAS DRILLED OUT TO 65. CEMENT GROUT WAS PUMPED FROM BOTTOM TO SURFACE. AUGER BIT WAS USED REPLACEMENT WELL WAS DRILLED 8' AWAY.				

Date started 7-28, 19 99
Date completed 7-28, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 65 Feet Depth Cased ABANDON Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	65 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		3/16	1+	30

Perforations:
Type perforation GALVANIZED STEEL PIPE
Size perforation .020.
From 30 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 65
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS T. SPILOTRO (Contractor)
Address 1016 E. KATELLA AVE (Contractor)
ANAHEIM CA 92805
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1421 29
Signed Thomas T. Spilotro (By driller performing actual drilling on site or contractor)
Date 8-16-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627