WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 76564
Permit No.
Basin 212

NOTICE OF INTENT NO. 18584

1. OWNER ~~DOW INDUSTRIES~~
MAILING ADDRESS ~~2606 E. LAMADRE WAY~~
~~LAS VEGAS, NV 89031~~

ADDRESS AT WELL LOCATION BOULDER HWY & RUSSELL
~~LAS VEGAS, NV~~

2. LOCATION NW ¼ NE ¼ Sec. 27 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. DW1096 Issued by Water Resources
161-34-501-002 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Abandon 14-dewater wells | | | | |
| Well # 1-14 | | | | |
| Drilled to depth with casing | | | | |
| pulled. | | | | |
| Filled with 3.5 yards 9 sack | | | | |
| cement slurry for each well. | | | | |

Date started 6/25, 1999
Date completed 6/30, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 24" Inches | 0 Feet | 30 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 36.71 | .250 | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type perforation MACHINE
Size perforation 3/16X2 1/2X14 AROUND
From 30 feet to 0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 0 feet to 30 feet

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. Contractor
Address 4847 S. VALLEY VIEW Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376
Signed By driller performing actual drilling on site or contractor
Date 7-30-99

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627