


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



NOTICE OF INTENT NO. **39835**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

OWNER Jerry Miller  
 MAILING ADDRESS 1683 Windmill  
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 1683 Windmill,  
Gardnerville, NV 89410

2. LOCATION NW 1/4 NW 1/4 Sec. 33 T 13 N/S R 21 E Douglas County  
 PERMIT NO. 23-160-25  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay		0	3	3
Sand		3	9	6
Course Gravel		9	15	6
Sandy clay		15	30	15
Sand & fine gravel		30	32	2
Sand, gravel & cobbles		32	36	4
Fine gravel & cobbles		36	70	34
Sand & Course Gravel		70	85	15
Sand & fine gravels		85	115	30
Sand & course gravel	x	115	145	30
Clay & sand		145	155	10
Clay		155	195	40
Sand & gravel	x	195	197	2
Clay		197	212	15
Fine sand	x	212	245	33

8. WELL CONSTRUCTION

Depth Drilled 245 Feet Depth Cased 245 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0	70
9 7/8 Inches	70	245

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	245

Perforations:  
 Type perforation Factory  
 Size perforation 3/32 x 3" single perf.  
 From 125 feet to 145 feet  
 From 225 feet to 245 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 54  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 54 feet to 245 feet

9. WATER LEVEL

Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality Not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.  
 Contractor

Address 1600 Mt. Rose Hwy  
 Contractor

Reno, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay  
 By driller performing actual drilling on-site or contractor

Date 5/13/99

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100+</u>		<u>3 hrs</u>