WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76574
Permit No.
Basin 105

NOTICE OF INTENT NO. 38850

1. OWNER Mark Gomez Construction
MAILING ADDRESS Stephanie Wy Minden NV. 89423
ADDRESS AT WELL LOCATION 2657 Wade Minden NV. 89423

2. LOCATION SW ¼ SE ¼ Sec. 34 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources | 21-213-060 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sands		0	6	6
Course DG Sands		6	43	37
Small Gravels		43	94	51
Brown Clay Stratas DG Sands		94	135	41
Fine Sands and Clay Seams (Silty)		135	149	14
Brown Solid Clay		149	154	5
Fractured Small Gravels DG Gravels	XX	154	180	26

RECEIVED 99 MAY 26 AM 8:48 STATE ENGINEER'S OFFICE

Date started 5-18, 1999
Date completed 5-19, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	30	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
13 3/8	13.03	.188	0	180

Perforations:
Type perforation Mill Slot
Size perforation 3x 3/32
From 160.0 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 56
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Capital City Well Drilling Contractor
Address 20 Kit Kat Contractor Carson City, NV. 89706

Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] By driller performing actual drilling on site or contractor
Date 5-19-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627