WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76586
Permit No.
Basin 92A

NOTICE OF INTENT NO. 40360

1. OWNER MARK & CATHY DORNSTAUDER
MAILING ADDRESS 8805 Little Creek Road, Reno, Nevada 89506
ADDRESS AT WELL LOCATION 10275 Pathfinder, Reno, Nevada 89506

2. LOCATION NE ¼ SE ¼ Sec. 14 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 087-060-08 (Parcel No.) Red Rock Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	18	17
Fine brown sand		18	21	3
Brown sandy clay		21	61	40
Brown clay		61	90	29
Soft zone (NO WATER)		90	92	2
Brown sandy clay		92	159	67
Brown clay		159	217	58
Soft zone (app 3 GPM)	X	217	221	4
BRown clay		221	246	25
Soft zone, granite sands	X	246	268	22
BRown sandy clay		268	275	7

99 JUN 7 PM 2:28
STATE ENGINEER'S OFFICE

Date started 6-1-99, 19
Date completed 6-2-99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	275 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	275

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 230 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 275 feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 4, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627