WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76686
Permit No.
Basin 212

NOTICE OF INTENT NO. 18586

1. OWNER TURNBERRY PARTNERS LLC
MAILING ADDRESS 2777 PARADISE RD.
LAS VEGAS, NV 89109

ADDRESS AT WELL LOCATION TURNBERRY PLACE
2777 PARADISE RD.
LAS VEGAS, NV 89109

2. LOCATION SW ¼ NE ¼ Sec. 9 T. 21 N/S R. 61 E. CLARK County

PERMIT NO. DW1101 (Issued by Water Resources) | 162-09-602-006 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
12-DEWATER WELLS				
Well #5-8				
Sandy clay		0	17'	
Wet loose clay & gravel		17'	21'	
Red sandy clay		21'	23'	
Caliche		23'	30'	

DCNR/DWR Received AUG 23 1999 LAS VEGAS OFFICE

Date started 7/22, 1999
Date completed 7/23, 1999

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24" Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.250	0	30

Perforations: MACHINE
Type perforation 1/4"X2 1/2" 16 ROWS
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 30 feet

9. WATER LEVEL

Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 18916

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376

Signed [signature] (By driller performing actual drilling on site or contractor)

Date 8-18-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627