



DEPARTMENT OF CONSERVATION AND NATURAL RESOURCES
DIVISION OF WATER RESOURCES

123 W. Nye Lane, Suite 246
Carson City, Nevada 89706-0818
(775) 687-4380 • Fax (775) 687-6972

February 15, 2000

Ken Stine
Public Health Investigator
Washoe County Environmental Health
P O BOX 11130
Reno, Nevada 89520

Re: Domestic well drilled for Julian Salmon, 2755 Paiute Creek Road, NW $\frac{1}{4}$ NW $\frac{1}{4}$
Section 22, T. 22N., R. 22E., MDM, Washoe County, Nevada

Dear Mr. Stine:

This is to confirm our telephone conversation regarding the 100-foot seal requirement for the above-referenced well, since it is located in an area of some mountain springs and/or a stream channel. I reviewed the well logs and I spoke with the well driller to confirm that the only water that was encountered in this hole was at the surface to 30 feet, where they had to set surface casing to control the caving condition, and at the 618-650 foot depth. After they set surface, the hole was literally dry to 618 feet. They then cased and cemented the annular space to 50 feet and pulled the surface casing. I believe this confirms the adequacy of the seal depth in this particular case. If you have any questions, please call me at 775-687-3861, or send a fax to 775-687-1393.

Very truly yours,

A handwritten signature in cursive script that reads "Thomas K. Gallagher".

Thomas K. Gallagher, P.E.
Senior Ground Water Engineer

Enclosure

cc: Aqua Drilling
Julian Salmon