RTP-12

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76641
Permit No.
Basin 72

NOTICE OF INTENT NO. 39968

1. OWNER APOLLO GOLD
MAILING ADDRESS P.O. BOX 330
IMLAY, NV 89418

ADDRESS AT WELL LOCATION FLORIDA CANYON
MINESITE, 8 MILES SW OF IMLAY, NV.

2. LOCATION NW ¼ NW ¼ Sec. 2 T. 31 N/S R. 33 E. PERSHING County

PERMIT NO. N/A (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALLUVIUM	540	0	585	585
CONSTRUCTION DETAIL:				
CEMENT		0	50	50
3/4" HOLE PLUG		50	80	30
ABANTONITE		80	335	255
GRAVEL PACK		335	585	250

RECEIVED 99 JUN -7 PM 2:39

Date started MAY 28, 19 99
Date completed MAY 30, 19 99

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 585 Feet Depth Cased 575 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	20 Feet
6 1/2 Inches	20 Feet	585 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7 5/8	29	0.375	0	22
2 3/8	1.29	SCH. 80	+1.5	575

Perforations:
Type perforation MILL SLOT
Size perforation 0.020"
From 475 feet to 495 feet
From 515 feet to 535 feet
From 555 feet to 575 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured SEE DETAIL
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 335 feet to 585 feet

9. WATER LEVEL
Static water level 368.7 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 80 °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address P.O. BOX 5279 (Contractor)
ELKO, NV 89802

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1772

Signed Rod Aders
By driller performing actual drilling on site or contractor

Date MAY 30, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627