WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
LK 41

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76648
Permit No.
Basin 51

NOTICE OF INTENT NO. 30129

1. OWNER Newmont Gold Co.
MAILING ADDRESS P.O. Box 669 Carlin NV 89822
ADDRESS AT WELL LOCATION at Gold Quarry Pit 8 Miles North of Carlin NV

2. LOCATION NE ¼ SW ¼ Sec. 2 T. 33 N/S R. 51 E. Eureka County
PERMIT NO. 56834 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	80'	80'
Alluvium Clay & Gravel		80'	595	515
Bed Rock		595'	605'	10'
Neat Cement		0	10'	10'
¾ Hole Plug		10	100	90'
on out Side of 16 5/8" Casing				
¾ Hole Plug		0	140'	140'
Pea Gravel		140	575	435'

Date started 3-24, 19 99
Date completed 4-6, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200'	5		5 min.
300'	30		5 min.
400'	60		5 min.
500'	70		5 min.
575'	70		5 min.

8. WELL CONSTRUCTION
Depth Drilled 605' Feet Depth Cased 575' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
16"	Inches	0	Feet	100	Feet
12"	Inches	100	Feet	605'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 5/8"		¼" wall	0	100'
8 5/8"	Blank	¼" wall	+2'	174'
8 5/8"	Screen	¼" wall	174'	575'

Perforations:
Type perforation Horz. Slots
Size perforation ⅛" Slots Lewness
From 174' feet to 575 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140 feet to 575 feet

9. WATER LEVEL
Static water level 166' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co. (Contractor)
Address 605 Union Pacific way (Contractor)
P.O. Box 2748 Elko NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1786
Signed Craig Diner (By driller performing actual drilling on site or contractor)
Date 4-6-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627