

199

PZ99-10

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 76665

Permit No. _____

Basin 61

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39963

1. OWNER BARRICK GOLDSTRIKE MINES ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE SITE, NORTH OF CARLIN, NV.
 MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

2. LOCATION SE 1/4 SW 1/4 Sec. 19 T 36 N3 R. 50 E EUREKA County
 PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAY & BLACK ROCK		0	75	75
BLACK ROCK		75	100	25
GRAY ROCK		100	140	40
BLACK ROCK		140	155	15
GRAY ROCK WITH CLAY		155	165	10
BLACK ROCK		165	290	125

8. WELL CONSTRUCTION

Depth Drilled 290 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

From	To
14.75 Inches	0 Feet 80 Feet
8.889 Inches	80 Feet 290 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75	40.48	0.375	0	80
1: 2.375	3.65	0.154	+3	270
2: 2.375	3.65	0.154	+3	210

CONSTRUCTION DETAIL:

CEMENT	0	50
HOLE PLUG	50	135
CEMENT	135	160
HOLE PLUG	160	165
GRAVEL PACK	165	215
CEMENT	215	223
HOLE PLUG	223	225
GRAVEL PACK	225	275
HOLE PLUG	275	290

Perforations: Type perforation SLOTTED
 Size perforation 1/8"

From 1: 230 feet to 270 feet
 From 2: 170 feet to 210 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped Poured

Gravel Packed: Yes No SEE DETAIL

Date started APRIL 28, 1999.
 Date completed APRIL 30, 1999.

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level: 1: DRY 2: 1.26 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature COOL °F Quality FAIR

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor
 Address P.O. BOX 5279 Contractor
ELKO, NV 89802

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2108

Signed Chris O'Brien
 By driller performing actual drilling on site or contractor

Date APRIL 30, 1999

B.S.T.L