



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39965

1. OWNER BARRICK GOLDSTRIKE MINES ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINESITE, NORTH OF CARLIN, NV.
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

2. LOCATION NW 1/4 NE 1/4 Sec. 30 T. 36 N. R. 50 E. EUREKA County
PERMIT NO. 55150 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
*NOTE: THIS WELL WAS ORIGINALLY CASED TO 679'. IT HAS BEEN MINED OFF, LEAVING 420' CASED, PRIOR TO THIS DEEPENING.				
GRAY AND BLACK GRANODIORITE		420	660	240

8. WELL CONSTRUCTION
Depth Drilled 660 Feet Depth Cased 660 Feet

HOLE DIAMETER (BIT SIZE)
From 8 Inches To 4.20 Feet 6.60 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	17.02	0.25	360	660

CONSTRUCTION NOTES:
1. THE ORIGINAL BOTTOM OF THE WELL WAS DRILLED OUT AND NEAT CEMENT PLACED BY TREMMIE FROM 420' TO 380', TO PREVENT THE GRAVEL PACK FROM BEING REMOVED DURING DRILLING.
2. WHERE THE TOP OF THE CASING REMAINED AFTER THE WELL WAS MINED OFF, THE GROUND WAS EXCAVATED TO 15' BELOW GRADE. THE ORIGINAL CASING WAS CUT OFF, AND 17' OF BLANK 8" CASING WELDED ON. THE EXCAVATION WAS THEN FILLED AROUND THE BLANK CASING WITH 270 CU. FT. OF NEAT CEMENT.

Perforations:
Type perforation LOUVER
Size perforation 0.125" X 2"
From 360 feet to 660 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal SEE NOTES Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 0 feet to 380 feet

Date started	Date completed
<u>MAY 3</u> , 19 <u>99</u>	<u>MAY 7</u> , 19 <u>99</u>

9. WATER LEVEL
Static water level 383.4 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature COOL °F Quality FAIR

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING Contractor
Address P.O. BOX 5279 Contractor
ELKO, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1888
Signed David Dorist
By driller performing actual drilling on site or contractor
Date MAY 7, 1999