


WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

Duzel Completion

STATE OF NEVADA
DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Permit No. 76724
Basin. 61

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39967

1. OWNER BARRICK GOLDSTRIKE MINES ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINESITE, NORTH OF CARLIN, NV.
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

2. LOCATION SW 1/4 SE 1/4 Sec. 19 T. 36 N. 50 E EUREKA County
PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary PVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLACK ROCK	1	0	365	365
BLACK & GREY ROCK	1	365	385	20
GREY ROCK	5	385	545	160
BLACK & GREY ROCK	32	545	625	80
BLACK & WHITE ROCK	48	625	655	30
GREY & BLACK ROCK		655		
TRACE OF CLAY			675	20
GREY, BLACK & GREEN ROCK, TRACE OF CLAY		675		
BLACK ROCK		700	750	50
BLACK ROCK WITH GREY CLAY		750	755	5
BLACK ROCK		755	785	30
GREY & BLACK FRACTURED ROCK		785		
GREY & BLACK ROCK		790	845	55
BLACK ROCK		845	1015	170
BLACK GREY ROCK		1015	1030	15
BLACK ROCK		1030	1115	85

8. WELL CONSTRUCTION
Depth Drilled 1,115 Feet Depth Cased 1,099 Feet
HOLE DIAMETER (BIT SIZE)
From 17.5 Inches To 0 Feet 50 Feet
10 Inches 50 Feet 1115 Feet
Inches.....Feet.....Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
13.375	68.75	0.500	0	45
1:2.375	3.65	0.154	+1	1099
2:2.375	3.65	0.154	+1	539

Perforations:
Type perforation SLOTTED
Size perforation 0.020"
From 1: 1079 feet to 1099 feet
From 2: 519 feet to 539 feet
From.....feet to.....feet
From.....feet to.....feet

Surface Seal: Yes No Seal Type:
Depth of Seal 52' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No SEE DETAIL
From.....feet to.....feet

9. 1: 394.6 WATER LEVEL 2: 260.5
Static water level.....feet below land surface
Artesian flow.....G.P.M.....P.S.I.
Water temperature.....°F Quality.....

Date started MAY 25, 1999
Date completed JUNE 3, 1999

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING Contractor
Address P.O. BOX 5279 Contractor
ELKO, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the 1995 Division of Water Resources, the on-site driller:
Signed Guadalupe Jacobo
By driller performing actual drilling on site or contractor
Date JUNE 3, 1999

214

B.S.T.L

