


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 76843  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19365

1. OWNER **PAHRUMP CONCRETE** ADDRESS AT WELL LOCATION **22 W KINGSTON**  
 MAILING ADDRESS **220 W KINGSTON**  
**PAHRUMP, NV 89041**

2. LOCATION **NE** 1/4 **NW** 1/4 Sec. **16** T **19S** N/S R **53E** E **NYE** County  
 PERMIT NO. **29-215-12** **COUNTRY PLACE II**  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other

4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	120	
CALICHIE	WB	120	132	12
CLAY		132	147	15
GRAVEL	WB	147	160	13
CLAY		160	173	13
CALICHIE	WB	173	185	12
CLAY		185	190	5

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10.25 Inches To 0 Feet  
 From 0 Feet To 190 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	190

Perforations:  
 Type perforation **SAW CUT**  
 Size perforation **1/8 X 3**

From 150 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 190 feet

9. WATER LEVEL  
 Static water level 98 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
 Address **P.O. BOX 4220** Contractor  
**PAHRUMP, NV. 89048**  
 Nevada contractor's license number issued by the State Contractor's Board **47333**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed Thomas Dan  
 By driller performing actual drilling on-site or contractor  
 Date **8/23/99**



Date started 8/16/99 19\_\_  
 Date completed 8/20/99 19\_\_

7. WELL TEST DATA

TEST METHOD:  Baller  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

