WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76893
Permit No.
Basin 107

NOTICE OF INTENT NO. 281 ~~80~~ 281 80

1. OWNER Pat & Gennie Mulrainey
MAILING ADDRESS 70 Miller Ridge Rd. Wellington NV. 89444
ADDRESS AT WELL LOCATION 40 Miller Ridge Rd Wellington NV. 89444

2. LOCATION NE ¼ NE ¼ Sec. 13 T. 11 N/S R. 23 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 10-281-07 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other N/A

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tripped To Bottom of old 8" Well 217'. Tryed to Blow Water Out and Did, Then the Well Just Made Sandy Very Little Water, Cleaned out. RAN 8" Well Perforator From Top 50' to Bottom of Well. Except Last 20' Perforated Area. Placed Trimming Pipe to Bottom of Well and Pumped Full of Cement.	6 Sacks of Neat Cement to 5.2 gallons of water Per BAG Alittle over 2 Pallets of Cement 66 Bags.			

Date started 8-29, 1999
Date completed 8-29, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Dry	N/A.	N/A.

8. WELL CONSTRUCTION
Depth Drilled N/A Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)
From To
Inches N/A Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		N/A		

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured N/A
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 189 feet below land surface
Artesian flow G.P.M. Dry P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat DR. Contractor
Carson City NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 8-29-99

RECEIVED 99 OCT -1 AM 9:5 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627