WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76897
Permit No.
Basin 107

NOTICE OF INTENT NO. 37599

1. OWNER Jesy Castayoda
MAILING ADDRESS #6 Agate
Yerington, Nev

ADDRESS AT WELL LOCATION Lower Colony
Lot #1
Wellington, Nev 89444

2. LOCATION SW ¼ NW ¼ Sec 22 T 11 N/S R 023 E Lyon County

PERMIT NO. ____ Issued by Water Resources | 10-291-12 Parcel No. | Santa Theresa Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
dg Top Soil		0	5	5
		~~5~~	~~12~~	
HARD PAN		5	12	7
yellow Sandy clay		12	35	23
Sand & gravel	yes	35	87	52
Sandy Clay		87	95	8
COARSE SAND	yes	95	115	20

RECEIVED 99 JUN 25 AM 10:56 [illegible]

Date started May 17, 1999, 19
Date completed May 25, 1999, 19

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	0	3

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
6 Inches	50 Feet	115 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
~~6/58~~		~~188~~	~~0~~	~~115~~
6/58		188	0	115

Perforations:
Type perforation factory saw slot
Size perforation 3/32 x 3
From 80 feet to 115 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling
Contractor
Address P.O. Box 92
Contractor
Smith, Nev 89430
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller
By driller performing actual drilling on site or contractor
Date 6-22-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627