WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76714
Permit No.
Basin 104

NOTICE OF INTENT NO. 34823

OWNER Ed & Gail Hamlin
MAILING ADDRESS 2250 S. Edmonds
Carson City, NV 89702

ADDRESS AT WELL LOCATION 2250 S. Edmonds

2. LOCATION NE 1/4 NE 1/4 Sec. 21 T 15N N/S R 20E E Carson County
PERMIT NO. (Issued by Water Resources) | 10-061-73 (Parcel No.) | (Subdivision Name)

3. WORK PERFORMED
- [ ] New Well
- [ ] Replace
- [ ] Recondition
- [ ] Deepen
- [x] Abandon
- [ ] Other

4. PROPOSED USE
- [x] Domestic
- [ ] Irrigation
- [ ] Test
- [ ] Municipal/Industrial
- [ ] Monitor
- [ ] Stock

5. WELL TYPE
- [x] Cable
- [ ] Rotary
- [ ] RVC
- [ ] Air
- [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 6 5/8" x 110' water well by perforating above the existing perforations from 60' to 48' where we hit the sanitary seal. We then pumped approximately 35 sacks of neat cement at 5 gal./sack by tremie from bottom to top. We cut the top 2 feet off of the casing. Static water level was 70' from top prior to perforating and 37 feet after perforating.				

Date started 9/9/99, 19__
Date completed 9/9/99, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	110

Perforations:
Type perforation Mills Knife
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [x] No
Depth of Seal
Placement Method: [x] Pumped [ ] Poured
Seal Type: [x] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 9/10/99

USE ADDITIONAL SHEETS IF NECESSARY