WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76934
Permit No.
Basin 92A

NOTICE OF INTENT NO. 39844

1. OWNER Wayne Cobb
MAILING ADDRESS 5215 Carol Dr.
Sun Valley, NV 89433

ADDRESS AT WELL LOCATION 10120 Trail Dr. Reno, NV 89506

2. LOCATION SW 1/4 SE 1/4 Sec. 1 T 20N N/S R 18E E Washoe County
PERMIT NO. WaCo#6302 (Issued by Water Resources) 81-031-24 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 6 5/8" well which was 107' deep and static water level of 78'. We entered the well and cleaned out wood, clay, gravel to 127. We tremied and pumped 16 sacks of neat cement which displaced the fluid. We then pulled the 6 5/8" casing from the well. We then poured approx. 2 yards of 6 sack 3/4" cement from top and filled the rest of the hole. We then pulled the 8" conductor casing. We found that the 8" casing was only 10' deep. The casing had not broken to the best of our judjement because the end of the casing was not sheerred and did not appear broken. The annular space that we measured betweent he 6 5/8" well casing and the borhole was only cased the first 10' and then open hole to about 60'.				

Date started 6/11/99, 19__
Date completed 6/14/99, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
/		/

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce Mackay (By driller performing actual drilling on-site or contractor)
Date 6/5/99

USE ADDITIONAL SHEETS IF NECESSARY