

OFFICE USE ONLY  
 Log No. **76937**  
 Permit No. \_\_\_\_\_  
 Basin **203**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **19955**

1. OWNER **Jim Wilkin**  
 MAILING ADDRESS **Box 828 Antelope Canyon Caliente NV 89008**  
 ADDRESS AT WELL LOCATION **mile marker 106.8 US 93 1 mile south of Pansy**  
 2. LOCATION **S/E 1/4 N/W 1/4 Sec. 18 T. 2 N. R. 68 E. Lincoln** County  
 PERMIT NO. **12-190-05**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand-Boulders streaks clay		0	110	110
Cemented Gravel		110	143	33
Clay-Boulders	X	143	185	42
gravel-sand-Boulders	X	185	192	7
Clay-Boulders		192	200	8

8. WELL CONSTRUCTION  
 Depth Drilled **200** Feet Depth Cased **200** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From **13 1/2** Inches To **0** Feet **200** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>8 3/8</b>	<b>c</b>	<b>1 7/8</b>	<b>0</b>	<b>200</b>

Perforations:  
 Type perforation **Factory**  
 Size perforation **1 5/8 x 1 1/2"**  
 From **100** feet to **120** feet  
 From **140** feet to **160** feet  
 From **180** feet to **200** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **50** feet to **200** feet

Date started **9-16-89**, 19\_\_\_\_  
 Date completed **10-4-89**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>30</b>	<b>6</b>	<b>5</b>

9. WATER LEVEL  
 Static water level **92** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **cold** °F Quality **fair**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Davis Drilling and Pumps** Contractor  
 Address **P.O. Box 54 Hiko NV 89001** Contractor  
 Nevada contractor's license number issued by the State Contractor's Board **0028966**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1191**  
 Signed **Mike Davis**  
 By driller performing actual drilling on site or contractor  
 Date **10-6-89**