

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42815

1. OWNER TIM & HEATHER CURRY ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 11950 Overland Road
Reno, Nevada 89506
 2. LOCATION NW 1/4 NW 1/4 Sec. 15 T. 21N N/S R. 19 E Washoe County
 PERMIT NO. 080-385-11 Lemmon Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Static water leve @285 feet				
Total depth @295 feet. Yield only a mist.				
Fracture rock (app 1.5 GPM)		295	297	2
Gray granite		297	328	31
Fracture (NO WATER)		328	330	2
Gray granite		330	336	6
Weathered granite		336	356	20
Fracture (NO WATER)		356	357	1
Weathered granite		357	381	24
Rusty weathered granite		381	395	14
Gray granite		395	405	10
Fracture (NO WATER)		405	406	1
Gray granite		406	448	42
Fracture (app 3 GPM)	X	448	449	1
Gray granite		449	469	20
Soft fractured granite w/clay streaks(1 GPM?)		469	491	22
Gray granite		491	500	9

NOTE: Bore hole caved in from 396 to 500 feet. At 336 ft. the 5" casing (liner) was collapsed from rock wedging against pipe. Casing could not be pulled or back driven from bore hole. Consider using well as is rather than pulling casing in two.

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 396 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches 295 Feet 500 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	396

Perforations: factory sawed slot
 Type perforation _____
 Size perforation 3/32 x 3 x 5 around
 From 196 feet to 216 feet
 From 276 feet to 296 feet
 From 336 feet to 356 feet
 From 371 feet to 391 feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal deepening Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 285 feet below land surface
 Artesian flow _____ G.P.M. 3+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Helman By driller performing actual drilling on site or contractor
 Date September 20, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>3+</u>	<u>50 ft</u>	<u>87 min</u>