

OFFICE USE ONLY
 Log No. 76986
 Permit No. _____
 Basin 923

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42814

1. OWNER CATHY KUPIHEA ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 11820 Fir Drive
Reno, Nevada 89506
 2. LOCATION SE 1/4 NW 1/4 Sec. 15 T 21N N/S R 19 E Washoe County
 PERMIT NO. 080-382-03 Lemmon Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Static water level @160 feet. Clean bottom at 175 feet. Yield maybe 2 GPM.				
Gray granite		175	189	14
Fractured granite	X	189	193	4
Gray granite		193	206	13
Fracture	X	206	207	1
Gray granite		207	229	22
Fracture	X	229	231	2
Gray granite		231	255	24
Fracture	X	255	256	1
Gray granite		256	283	27
Fracture granite		283	285	2

8. WELL CONSTRUCTION
 Depth Drilled 285 Feet Depth Cased 285 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches 175 Feet 285 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	285

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 180 feet to 200 feet
 From 220 feet to 240 feet
 From 260 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal deepening Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 175 feet to 285 feet

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I.
 Water temperature cold °F Quality clear

Date started Sep. 13 1999
 Date completed Sep. 14 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date September 20, 1999