WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76995
Permit No.
Basin 157

NOTICE OF INTENT NO. 32380

1. OWNER LEROY ETCHEGARY
MAILING ADDRESS BOX 477
EUREKA NEV. 89316

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 5 T. 22 N R. 54 E EUREKA County
PERMIT NO. 19360 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sand Gravel		2	25	23
Black clay.		25	69	44
" Sand Gravel		69	78	9
CLAY		78	137	59
Sand Gravel.	7	137	144	7
CLAY		144	157	13
Sand Gravel	13	157	170	13
Clay		170	173	3
Sand Gravel.	4	173	177	4
Clay.		177	246	69
Sand Gravel	5	246	251	5
Clay		251	281	30
Sand Gravel.	3	281	284	3
Clay.		284	341	57
hard Brown chippy		341	368	27
sand stone.	~~3~~	~~368~~	~~371~~	~~3~~
Sand Gravel	3	368	371	3
hard chippy clay		371	385	14
hard and Soft layers of clay		385	415	30
Sand Gravel	5	415	420	5
Clay.		420	426	6
hard and Soft clay		426	450	24
Sand and Gravel	4	450	454	4
Clay.		454	475	21

Date started 4-15-99, 19
Date completed 4-17-99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO	TEST	

8. WELL CONSTRUCTION
Depth Drilled 475 Feet Depth Cased 475 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
38 Inches		0 Feet	51 Feet
27 Inches		51 Feet	475 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		.250	0	240
12"		.250	240	475

Perforations:
Type perforation ROSCO MOSS
Size perforation ⅛
From 138 feet to 178 feet
From 240 feet to 250 feet
From 280 feet to 300 feet
From feet to feet
From 340 feet to 390 feet
~~415~~ 455

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 475 feet

9. WATER LEVEL
Static water level 21' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WALT PLASKETT (Contractor)
Address BOX 10 (Contractor)
EUREKA, NEV. 89316
Nevada contractor's license number issued by the State Contractor's Board 11868
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 635
Signed James E. Plath (By driller performing actual drilling on site or contractor)
Date 5-8-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627