

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 No. 76-978  
 Permit No. 64504  
 Basin 2  
 NOTICE OF INTENT NO. 40841

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Nevada 1st. Corp. ADDRESS AT WELL LOCATION Hwy 95 & State Rte 290  
 MAILING ADDRESS P.O. Box 490  
Winnemucca, NV 89446  
 2. LOCATION NE 1/4 SW 1/4 Sec. 3 T 39 N/S R 38 E Humboldt County  
 PERMIT NO. 64504 Parcel No. 6-081-03 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material                | Water Strata | From | To  | Thickness |
|-------------------------|--------------|------|-----|-----------|
| Top Soil                |              | 0    | 6   |           |
| gravel                  |              | 6    | 38  | 32        |
| gravel w/clay           |              | 38   | 65  | 27        |
| cobbles w/gravel & clay |              | 65   | 150 | 85        |
| fractured rock          |              | 150  | 225 | 75        |
| rock w/clay stringers   |              | 225  | 280 | 55        |
| Fractured rock          |              | 280  | 306 | 26        |
| sand & clay             |              | 306  | 380 | 74        |
| clay                    |              | 380  | 393 | 13        |
| sand & clay             |              | 393  | 465 | 72        |

8. WELL CONSTRUCTION  
 Depth Drilled 465 Feet Depth Cased 458 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
13 Inches 0 Feet 50 Feet  
12-1/4 Inches 50 Feet 465 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>8-5/8</u>       |                     | <u>.188</u>             | <u>+2</u>   | <u>458</u> |

Perforations:  
 Type perforation Single row mill slot  
 Size perforation 1/8 x 3  
 From 378 feet to 458 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 63  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 63 feet to 465 feet

9. WATER LEVEL  
 Static water level 152 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc.  
 Contractor  
 Address 4675 W. Winnemucca Blvd  
 Contractor  
Winnemucca, Nevada 89445  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1154 T-1  
 Signed Jean A. Tomp  
 By driller performing actual drilling on-site or contractor  
 Date 4/22/99

Date started 4/14/99, 19\_\_\_\_  
 Date completed 4/19/99, 19\_\_\_\_

7. WELL TEST DATA

| TEST METHOD:   | Draw Down (Feet Below Static) |  | Time (Hours)  |
|--|-------------------------------|--|---------------|
|  | G.P.M.                        |  |               |
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>20</u>                     |  | <u>5 hrs.</u> |