

OFFICE USE ONLY
 Log No. 77010
 Permit No. _____
 Basin 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21277

1. OWNER Tom Hamilton ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 34 A South Bybee Ln
Yerington NV 89449
 2. LOCATION NW 1/4 NW 1/4 Sec 2 T. 13 N. R. 26 E. Lyon County
 PERMIT NO. 14-652-21 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MWD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil - Sandy</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Coarse Sand - Gravel</u>				
<u>Rock</u>		<u>2</u>	<u>110</u>	<u>108</u>
<u>Coarse Sand - Gravel -</u>				
<u>Few Rock</u>		<u>110</u>	<u>182</u>	<u>72</u>
<u>Coarse Sand - Gravel -</u>				
<u>Rock</u>	<u>X</u>	<u>182</u>	<u>199</u>	<u>17</u>

8. WELL CONSTRUCTION
 Depth Drilled 199 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 199 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>199</u>

Perforations:
 Type perforation Sawed
 Size perforation 3 3/4 x 3" x 6 Rows
 From 199 feet to 199 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 199 feet

9. WATER LEVEL
 Static water level 97' 6" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 12-15, 1994
 Date completed 12-20, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Perked</u>	<u>20</u>	<u>7' 6"</u>	<u>1 HR</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. Bybee Ln. Contractor
Yerington NV. 89449
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Lg. Ogden
 By driller performing actual drilling on site or contractor
 Date 6-26-99