

OFFICE USE ONLY  
 Log No. 77011  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25123

1. OWNER Randy Page ADDRESS AT WELL LOCATION 15 N. By Bee Ln  
 MAILING ADDRESS Yerington NV Yerington NV 89447  
 2. LOCATION NW 1/4 SW 1/4 Sec 3 T. 13 N. R. 26 E. Lyon County  
 PERMIT NO. 14-641-13 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

| Material              | Water Strata | From | To  | Thick-ness |
|-----------------------|--------------|------|-----|------------|
| Top Soil-Clay Sh      |              | 0    | 4   | 4          |
| Coarse Sand           |              | 4    | 16  | 12         |
| Clay-Sand             |              | 16   | 52  | 36         |
| Coarse Sand-Gravel    |              | 52   | 66  | 14         |
| Clay-Gravel           |              | 66   | 78  | 12         |
| Coarse Sand-Gravel    |              | 78   | 92  | 14         |
| Coarse Sand-Gravel    |              |      |     |            |
| Few Rock              | X            | 92   | 116 | 24         |
| Coarse Sand-Gravel    |              |      |     |            |
| Rock                  | X            | 116  | 123 | 7          |
| Coarse Sand-Fractured |              |      |     |            |
| Rock                  | X            | 123  | 125 | 2          |
| Brown clay            |              | 125  | 126 | 1          |

8. WELL CONSTRUCTION  
 Depth Drilled 126 Feet Depth Cascd 127 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 7/8 Inches To 0 Feet 126 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 3/8</u>       | <u>12.92</u>        | <u>.188</u>             | <u>71</u>   | <u>127</u> |

Perforations:  
 Type perforation Sawed  
 Size perforation 3/32 X 3" X 6 Rows  
 From 106 feet to 126 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 126 feet

9. WATER LEVEL  
 Static water level: 43 feet below land surface  
 Artesian flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started 8-2 1995  
 Date completed 8-8 1995

7. WELL TEST DATA

| TEST METHOD:  | G.P.M.    | Draw Down (Feet Below Static) | Time (Hours) |
|---|-----------|-------------------------------|--------------|
| <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift |           |                               |              |
| <u>Bailed</u>   | <u>25</u> | <u>9</u>                      | <u>1 HR</u>  |
| <u>Air lift</u>   | <u>40</u> | <u>100' line</u>              | <u>1 HR</u>  |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Orden Bros Drilling Contractor  
 Address 162 N. By Bee Ln Contractor  
Yerington NV 89447  
 Nevada contractor's license number issued by the State Contractor's Board: 15646  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 634  
 Signed Lay Orden  
 By driller performing actual drilling on site or contractor  
 Date 6-29-99