WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77013
Permit No. 62495
Basin 108

NOTICE OF INTENT NO. 25166

1. OWNER Lotus Rubert
MAILING ADDRESS 30 Almond Dr.
Yerington NV 89447

ADDRESS AT WELL LOCATION 1 Will Hoyt Ln
Yerington NV 89447

2. LOCATION NE ¼ NW ¼ Sec. 9 T. 13 N/S R. 26 E. Lyon County
PERMIT NO. 62495 (Issued by Water Resources) 14-322-07 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic Cafe ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Brown Clay		3	10	7
Fine-Coarse Sand-Small Gravel		10	18	8
Brown Clay		18	22	4
Fine-Coarse Sand-Small Gravel		22	45	23
Brown Clay-Coarse Sand Fill		45	60	15
Brown Clay		60	68	8
Fine-Coarse Sand-Fill		68	80	12
Coarse Sand-Small Gravel Fill		80	92	12
Coarse Sand-Clay		92	102	10
Brown Clay-Coarse Sand-Small Gravel		102	108	6
Coarse Sand-Small Gravel-Few Rock Fill		108	120	12
Coarse Sand-Gravel-Few Rock Fill		120	128	8
Coarse Sand-Gravel Clay Fill		128	150	22
Coarse Sand-Gravel Fill	X	150	158	8
Coarse Sand-Gravel-Rock Fill	X	158	178	20

Date started 6-11, 1999
Date completed 6-20, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift	150	100' Line	3 HR

8. WELL CONSTRUCTION
Depth Drilled 178 Feet Depth Cased 179'6" Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12 3/4	0	178

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1.5	179

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 8 Rows
From 159 feet to 179 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 179 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Ln. (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-30-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627