WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77014
Permit No.
Basin 108

NOTICE OF INTENT NO. 27278

1. OWNER William LaTTin
MAILING ADDRESS P.O. Box 15585
Las Vegas NV 89114

ADDRESS AT WELL LOCATION 2 THURSTON
Yerington NV 89447

2. LOCATION SW ¼ NW ¼ Sec. 9 T. 13 N/S R. 26 E. Lyon County
PERMIT NO. — Issued by Water Resources
Parcel No. 14-601-40
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clayish		0	5	5
Coarse Sand		5	8	3
Brown clay		8	10	2
Coarse Sand-Gravel		10	16	6
Brown Clay		16	24	8
Coarse Sand - Clay		24	30	6
Coarse Sand-Gravel		30	36	6
Clay - Coarse Sand		36	54	18
Coarse Sand-Gravel		54	68	14
Clay - Sand		68	72	4
Coarse Sand-Gravel-Clay		72	80	8
Coarse Sand-Gravel-Rock-Clay		80	90	10
Clay-Coarse Sand-Gravel		90	105	15
Coarse Sand-Gravel		105	110	5
Clay - Coarse Sand		110	120	10
Sand - Gravel		120	140	20
Coarse Sand-Gravel-Rock - Clay		140	161	21
Coarse Sand-Gravel-Rock	X	161	179	18

Date started 12-21, 1994
Date completed 12-26, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	40	16	1 HR
Air lift	50	160' Line	1 HR

8. WELL CONSTRUCTION
Depth Drilled 179 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	179

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.72	.188	+1	179

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 59 feet to 179 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 179 feet

9. WATER LEVEL
Static water level 34 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. By Bee Ln (Contractor)
Yerington NV 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Lay Ogden (by driller performing actual drilling on site or contractor)
Date 6-26-99

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627