



Log No. 77015
 Permit No. 1008
 Basin 1008

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25125

1. OWNER Herman De Witt ADDRESS AT WELL LOCATION 13 Will Hoyt Ln.
 MAILING ADDRESS 25 Will Hoyt Ln. Yerington NV 89442
 2. LOCATION SE 1/4 NW 1/4 Sec. 9 T. 13 N. R. 26 E. Lyon County
 PERMIT NO. 14-601-47 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sandy Clay		0	3	3
Clay - Sand Strata		3	10	7
Coarse Sand		10	15	5
Clay - Sand		15	35	20
Coarse Sand - Gravel		35	45	10
Coarse Sand - Gravel - Clay		45	55	10
Clay - Sand		55	65	10
Clay		65	68	3
Sand		68	72	4
Sand - Clay		72	85	13
Coarse Sand - Gravel		85	90	5
Coarse Sand - Gravel - Small Clay Strata		90	96	6
Coarse Sand - Gravel		96	120	24
Few Rock		96	120	24
Coarse Sand - Gravel - Rock		120	139	19
Coarse Sand - Gravel X		139	159	20

8. WELL CONSTRUCTION
 Depth Drilled 159 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 1/8 Inches To 0 Feet 159 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.168</u>	<u>1</u>	<u>160</u>

Perforations:
 Type perforation Sawed
 Size perforation 9 3/4 x 3" x 6 Rows
 From 139 feet to 159 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 159 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. By Bee Ln
Yerington NV 89442
 Nevada contractor's license number 15646
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 634
 Division of Water Resources, the on-site driller
 Signed Lo Ogden
 _____ driller performing actual drilling on site or contractor
 Date 6-29-99

Date started 9-6 1995
 Date completed 9-11 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Bailed</u>	<u>25</u>	<u>3</u>	<u>1 HR</u>
<u>AIR LIFT</u>	<u>50</u>	<u>100' line</u>	<u>1 HR</u>